

GWS-33
10/94

STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

For Official Use Only

RECEIVED

MAY 04 1998

WATER RIGHTS DIVISION
STATE ENGINEER
COLORADO

1. WELL PERMIT NUMBER 202761

2. OWNER NAME(S) PETER LEIGH TAYLOR

Mailing Address 504 SMITH ST

City, St Zip FT COLLINS CO 80524

Phone (970) 416-0232

3. WELL LOCATION AS DRILLED: NW 1/4 NW 1/4, Sec. 23 Twp. 7 N Range 70 W

DISTANCES FROM SEC. LINES:

750 ft from NORTH Sec. line, and 650 ft from WEST Sec. line. OR
(north or south) (east or west)

SUBDIVISION: REDSTONE CANYON

LOT 37 BLOCK FILING(UNIT)

STREET ADDRESS AT WELL LOCATION:

4. GROUND SURFACE ELEVATION ft DRILLING METHOD AIR-PERCUSSION

DATE COMPLETED 3-24-98 TOTAL DEPTH 500 ft DEPTH COMPLETED 500 ft

5. GEOLOGIC LOG:

Depth Description of Material (Type, Size, Color, Water Location)

0-30 BROWN DECOMPOSED FIRM

30-100 GRAY GRANITE FIRM

100-150 PINK GRANITE FIRM

150-280 BLACK SCHIST HARD

280-320 PINK SCHIST FIRM

320-500 BLACK SCHIST HARD X

6. HOLE DIAM. (in.) From (ft) To (ft)

10 0 20
6 20 500

7. PLAIN CASING

OD (in) Kind Wall Size From(ft) To(ft)
6-5/8 STEEL .188 0 20

OPEN HOLE

PERF. CASING: Screen Slot Size:

The testing of production of water from this well, as reflected by this report, is totally dependent upon conditions existing as of the date of testing and does not reflect any projection as to future production. This is dependent on future conditions.

REMARKS:

8. FILTER PACK:

Material
Size
Interval

9. PACKER PLACEMENT:

Type
Depth

10. GROUTING RECORD:

Material Amount Density Interval Placement
NEAT CEMENT 3-BAGS 17-GAL 20' MIXED & POURED

11. DISINFECTION: Type Amt. Used 2.5-CUPS

12. WELL TEST DATA: ☐ Check box if Test Data is submitted on Form No. GWS 39 Supplemental Well Test.

TESTING METHOD AIR-LIFT

Static Level 484 ft. Date/Time measured 3-24-98, Production Rate 12 GPH

Pumping level 500 ft. Date/Time measured 3-24-98, Test length (hrs.) 2 gpm.

Remarks

13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]

CONTRACTOR INGRAM DRILLING, INC. Phone (970) 586-4542 Lic. No. 1099

Mailing Address P O BOX 342 ESTES PARK CO 80517

Name/Title (Please type or print)

Signature

Date

STEPHEN E INGRAM PRESIDENT

4-22-98