

FORM NO.
6W6-22
10/64

PUMP INSTALLATION AND TEST REPORT
STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

For Office Use only

RECEIVED

FEB 08 1999

WATER RESOURCES
STATE ENGINEER
COLO.

1. WELL PERMIT NUMBER 202761

2. OWNER NAME(S) Peter Leigh Taylor
Mailing Address 504 Smith St
City, St. Zip Ft Collins, CO 80524
Phone (970) 416-0232

3. WELL LOCATION AS DRILLED: NW 1/4 NW 1/4, Sec. 23 Twp. 7 N, Range 70 W
DISTANCES FROM SEC. LINES:
750 ft. from North Sec. line. and 650 ft. from West Sec. line.
(North or South) (East or West)
SUBDIVISION: Redstone Canyon LOT BLOCK FILING(UNIT)
STREET ADDRESS AT WELL LOCATION:

4. PUMP DATA: Type Submersible Installation Completed 12-1-98
Pump Manufacturer Goulds Pump Model No. 5GS07412
Design GPM 5 at RPM 3450, HP 3/4, Volts 230, Full Load Amps 8
Pump Intake Depth 440 Feet, Drop/Column Pipe Size 1 Inches, Kind PVC

ADDITIONAL INFORMATION FOR PUMPS GREATER THAN 50 GPM:

TURBINE DRIVER TYPE: ☐ Electric ☐ Engine ☐ Other
Design Head feet, Number of Stages , Shaft size inches.

5. OTHER EQUIPMENT:

Airline Installed ☐ Yes ☐ No, Orifice Depth ft. , Monitor Tube Installed ☐ Yes ☐ No, Depth ft.
Flow Meter Mfg. Meter Serial No.
Meter Readout ☐ Gallons, ☐ Thousand Gallons, ☐ Acre feet, ☐ Beginning Reading

6. TEST DATA: ☐ Check box if Test data is submitted on Supplemental Form.

Date 12-1-98
Total Well Depth 460' Time 1:00
Static Level 40' Rate (GPM) 5
Date Measured 12-1-98 Pumping Lvl. 440'

7. DISINFECTION: Type Liquid Chlorine Amt. Used 1 1/2 Gallons

8. Water Quality analysis available. ☐ Yes ☒ No

9. Remarks

10. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge.
[Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]

CONTRACTOR Front Range Well Service, Inc Phone (970) 482-7650 Lic. No. 1323
Mailing Address P.O. Box 6009 Loveland, CO 80538

Name/Title (Please type or print)
Mike Overly/Owner

Signature

Mike Overly

Date

2-3-99